



State Water Resources Control Board

REVIEW SUMMARY REPORT – ADDITIONAL WORK
FOURTH REVIEW – AUGUST 2014

Agency Information

Table with 2 columns: Agency Name, Address, Agency Caseworker, Case No.

Case Information

Table with 2 columns: USTCF Claim No., Site Name, Responsible Party, USTCF Expenditures to Date, GeoTracker Global ID, Site Address, Address, Number of Years Case Open

To view all public documents for this case available on GeoTracker use the following URL.

URL: http://geotracker.waterboards.ca.gov/profile\_report.asp?global\_id=T0601900658

Summary

The Low-Threat Underground Storage Tank (UST) Case Closure Policy (Policy) contains general and media-specific criteria, and cases that meet those criteria are appropriate for closure pursuant to the Policy. This case does not meet all of the required criteria of the Policy. Highlights of the case follow:

This case is an active commercial petroleum fueling facility and truck stop. An unauthorized release was reported in September 1998. Soil vapor extraction was conducted between July 2006 and June 2011, which removed 18,560 pounds of total petroleum hydrocarbons as gasoline (TPHg). Ozone injection was conducted between January 2009 and October 2011. No active remediation has been conducted in over two years. Since 2002, 10 groundwater monitoring wells have been installed and monitored. According to groundwater data, water quality objectives have been achieved or nearly achieved for all constituents.

The petroleum release is limited to the soil and shallow groundwater. According to data available in GeoTracker, there are two public water supply wells within 1,000 feet of the projected plume boundary. Ten domestic wells have been identified within 1,000 feet of the projected plume boundary in files reviewed. There are no surface water bodies within 1,000 feet of the projected plume boundary. The unauthorized release is located within the service area of a public water system, as defined in the Policy.

